

- Weir in the parking surface will create the detention rate but will create a possible issue with the 9 inch depth

Mr. Storm asks what the standard is as to how long is allow to drain back to the surface; Mr. Elkhoury responds 24 hours.

Chair Miller asks if the business owner is willing to take responsibility for vehicle damage due to flooding.

Mr. Mark Temple, Johnstone Supply comes to speak on the following:

- Johnstone Supply is building a distribution center
- Smaller site so probably no more than 3 or 4 cars on site at a time
- Takes full responsibility for any damage to vehicles

Mr. Storm asks about draining the 15 inches in 12 hours; Mr. Elkhoury responds that it can drain quicker if they open the weir so then the site won't be detaining that much; basically controlling the flow with the weir; and there are two weirs in place as one to control the 1, 2 up to 5 year then one above it for the 50 and 100 year.

Mr. Temple comments about the Owasso location using this same method; been there almost 7 years; and have never had an issue at this facility.

Chair Miller comments that it seems best to enhance the drainage from the parking lot by restraining the flow off of the site.

Discussion is held about this site drains into the street curb then to the west then to a flume into the lake before entering the stream system.

Chair Miller asks if there are any more questions or comments; none respond. Chair Miller closes the presentation and public hearing section of the meeting. Chair Miller asks if there is a motion.

Ms. Fong-Goddard moved, Mr. Mitchell seconded to approve the variance as requested.

Roll Call:	Miller	Storm	Daniels	Mitchell	Fong-Goddard
	Yes	Yes	Yes	Yes	Yes

Time: 28 minutes

3. APPROVAL OF MEETING SUMMARY:

- Regular Meeting Summary of August 28, 2018.

Chair Miller asks if there any changes and/or corrections; none respond.

Mr. Storm moved, Mr. Daniels seconded to approve the meeting summary of August 28, 2018.

Roll Call:	Miller	Storm	Daniels	Mitchell	Fong-Goddard
	Yes	Yes	Yes	Yes	Abstain

Time: 1 minute

b. Special Meeting Summary of July 28, 2020.

Chair Miller asks if there any changes and/or corrections; none respond.

Mr. Storm moved, Mr. Mitchell seconded to approve the meeting summary of July 28, 2020.

Roll Call:	Miller	Storm	Daniels	Mitchell	Fong-Goddard
	Yes	Yes	Yes	Yes	Yes

Time: 1 minute

c. Special Meeting Summary of December 17, 2020.

Chair Miller asks if there any changes and/or corrections; none respond.

Mr. Daniel moved, Ms. Fong-Goddard seconded to approve the meeting summary of December 17, 2020.

Roll Call:	Miller	Storm	Daniels	Mitchell	Fong-Goddard
	Yes	Abstain	Yes	Yes	Yes

d. Time: 1 minute


4. MISCELLANEOUS ITEMS FROM STAFF FOR DISCUSSION AND POSSIBLE ACTION:

- a. Next meeting Tuesday, May 25, 2021.

5. ADJOURN

ADJOURNMENT. This special meeting of the Stillwater Board of Drainage Appeals was called for adjournment by Ms. Fong-Goddard, seconded by Mr. Mitchell at approximately 6:03 PM on April 27, 2021, with all members present in agreement, the next regularly scheduled meeting will be held May 25, 2021 at 5:30 p.m. in Municipal Building, 723 South Lewis Street.

Prepared by Cindy Gibson, Administrative Services Manager


Chair